

WESTECK WINDOWS MFG. LTD.

TEST REPORT

TEST REPORT ISSUED TO

Westeck Windows Mfg. Ltd.
8104 Evans Road
Chilliwack, BC V2R 5R8
Canada

SPECIFICATION

AAMA/WDMA/CSA 101/I.S.2/A440-17
CSA A440S1-19

PRODUCT SERIES & TYPE

4300 Series Fixed Window

PRIMARY DESIGNATION

Class LC – PG30 – Size Tested 1828 x 3048 mm (72 x 120 in) – Type FW

SECONDARY DESIGNATION

Positive Design Pressure = 1440 Pa (30.1 psf)
Negative Design Pressure = 1440 Pa (30.1 psf)
Water Penetration Resistance = 720 Pa (15.2 psf)
Canadian Air Leakage Resistance = Fixed

REPORT NUMBER

105123058COQ-003

TEST DATE

07/27/22 - 08/19/22

ISSUE DATE

10/14/22

PAGES

26

DOCUMENT CONTROL NUMBER

GFT-OP-10c (AUG 21, 2020)
© 2017 INTERTEK

